



JDYX.E19180 Fuses, Miscellaneous, Miniature and Micro

Fuses, Miscellaneous, Miniature and Micro

Guide Information

COOPER INDUSTRIES INC
BUSSMANN DIV
PO BOX 14460
ST LOUIS, MO 63178 USA

E19180

Type or Cat. No.	Size	Amps	V AC
Miscellaneous, cartridge enclosed, nonrenewable:			
Cat. No. FNW	13/32 X 1-1/2 in.	12.0-30	250
Cat. No. KTK	13/32 X 1-1/2 in.	0-30	600
Cat. No. BBS	13/32 X 1-3/8 in.	0-5	600
Cat. No. BBS	13/32 X 1-1/2 in.	6-10	250
Cat. No. FNM	13/32 X 1-1/2 in.	0-10	250
Cat. No. FNM	13/32 X 1-1/2 in.	12-15	125
Cat. Nos. MIC, MIJ	13/32 X 1-1/2 in.	0-15	250
Cat. No. ADL	13/32 X 1-1/2 in.	0-15	250
Cat. No. FNQ	13/32 X 1-1/2 in.	0-30	500
Cat. No. FNA	13/32 X 1-1/2 in.	0.1-0.8	250
Cat. No. FNA	13/32 X 1-1/2 in.	1-15	125
Cat. No. FNJ	12/32 X 1-1/2 in.	0.1-6	250
Cat. No. FNJ	13/32 X 1-1/2 in.	6.3-15	125
Cat. No. BAF	13/32 X 1-1/2 in.	0-15	250
Cat. No. DCM	13/32 X 1-1/2 in.	1/10-30	600
Cat. No. DCM	13/32 X 1-1/2 in.	1/10-30	600dc
Miniature, cartridge enclosed, nonrenewable:			
Types MDL+, MDL-V	1/4 X 1-1/4 in.	1/16-8	250

Type MDV+	1/4 X 1-1/4 in.	1/16-8	250
with or without			
suffix RAD			
Types MDX+, MDX-V	1/4 X 1-1/4 in.	1/16-8	250
Types MDQ+, MDQ-V	1/4 X 1-1/4 in.	1/16-7	250
Type MDQ-V	1/4 X 1-1/4 in.	1/16-7	250
Type GBA	1/4 X 1-1/4 in.	0.5-5	125
Type GLD	1/4 X 1-1/4 in.	0.5-5	125
Type AGA+	1/4 X 5/8 in.	0 - 1-1/2	125
Type GKN	1/4 X 5/8 in.	0 - 1-1/2	125
Type MKB	1/4 X 1- in.	1/8, 1/16	250
Type AGC+	1/4 X 1-1/4 in.	1/500-10	250
Type GJV+ with or	1/4 X 1-1/4 in.	0-10	250
without			
suffix RAD			
Types ABC, ABC-V, GLW;	1/4 X 1-1/4 in.	0-15	250
Cat. No. WP-91768L			
followed by 101 thru 116;			
Cat. No. WP-91768L			
followed by 1 thru 16			
Type GLR	5/8 X 2-1/32 in.	0-15	300
Type GLQ	5/8 X 2-1/32 in.	0-10	300
Type GRR	5/8 X 2-1/32 in.	10.1-15	125
Type GMF	5/8 X 1-7/8 in.	1/4-10	300
Type GMQ	5/8 X 1-7/8 in.	1/4-6-1/4	300
Type GRF	5/8 X 1-7/8 in.	7-10	300
Type C	1/4 X 1-1/16 in.	1/64-31/2	250
Type C	1/4 X 1-1/4 in.	4-10	250
Type N	1/4 X 1-1/4 in.	1/100-11/4	250
Type N	1/4 X 1-7/16 in.	11/2-7	125
Type B	1/4 X 1-7/16 in.	3-2/10	125
Types AGX, AGX-V	1/4 X 1- in.	0-2	250
Types AGX, AGX-V	1/4 X 1- in.	2.1-5	125
Type MTH+	1/4 X 1-1/4 in.	4-8	250
Types MTH+, MTH-V	1/4 X 1-1/4 in.	3.5-8	250

-CW			
Type MBK	1/4 X 13/16 in.	0-3	250
Types GLH+, GLH-V	1/4 X 1-1/4 in.	7-10	125
Types MSL+, MSL-V	1/4 X 1-1/4 in.	1/10-8	250
Type MSV with or without suffix RAD	1/4 X 1-1/4 in.	1/10-8	250
Type MWO	1/4 X 1-1/4 in.	12 and 15	125
Types GMD, GMD-V	5 X 20 mm	0.1-3	125/250
Type AGA-V	1/4 X 5/8 in.	0-5	125
Type AGC-V	1/4 X 1-1/4 in.	0-10	250
Types MDA, MDA-V,	1/4 X 1-1/4 in.	0-15, 20	250
MDW			
Types MDA , MDA-V,	1/4 X 1-1/4 in.	20	125dc
MDW			
KLM-A	13/32 X 1-1/4 in.	8-15, 20-30	500Vac
KLM-A	13/32 X 1-1/4 in.	8-15, 20-30	400Vdc
MRCHV (Note 1)	2.42X7.1mm	0.100-0.315	120
		0.375-3.0	
MCRF (Note 1)	2.42X7.1mm	0.100-3.0	125 Vac
MRCHV (Note 1)	2.42X7.1mm	0.375-3.0	250Vac
GMA, GMA-V	5 x 20mm	3.1-6	125
GMA, GMA-V	5 x 20mm	0.05-3	125/250
GMD, GMD-V	5 x 20mm	0.1-3	125/250
GMB	5 x 20mm	1-3.15	250
GMB	5 x 20mm	1-3.15	125
GMC, GMC-V	5 x 20mm	0.05-3.15	125/250
GMC, GMC-V	5 x 20mm	3.5-6.3	125
TDC515, C515	5.5 x 15.2mm	0.125-3	125/250
C519	5 x 14.5mm	0.125-3	125/250
TDC517, C517	5.2 x 15.2mm	2-5	125/250
TDC518, C518	5.48 x 15.0mm	0.1-0.75	125/250
TDC518, C518	5.5 x 15.2mm	1.5-0.5	125/250
TDC520, C520	5.2 x 14.28mm	0.1-0.75	125/250
TDC520, C520	5.2 x 14.2mm	1.5-0.5	125/250
TDC520	5.22 x 15mm	4-5	125/250

TDC520	5.22 x 15mm	6-10	125
M515	5.5 x 16.5mm	0.125-3	125/250
Micro, nonrenewable:			
6125FA	0.1-12	125ac/86dc	
6125FA	0.1-7	125ac dc	

Note (1) - Non time delay.

+These fuses may be provided with the suffix letter "B" after the Cat. No. and before amp ratings.

LOOK FOR LISTING MARK ON PRODUCT

This page and all contents are Copyright © 2003 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained on UL's Website subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2003 Underwriters Laboratories Inc.®"