



## Certificate of Compliance

Item Tested: Pre-production samples of range of single-gang, switched socket-outlet rod's, all rated at 230V, 13A, with a rated tripping current of 30mA

Model: K21WA active, white plastic front-plate  
K21WP passive, white plastic front-plate  
K21MA active, metal-clad front-plate  
K21MP passive, metal-clad front-plate

No. of Samples Tested: 25 samples

Relevant Specification used as Basis of Tests: BS 7288 : 1990 (Amd 1)

This is to certify that, on the basis of the tests undertaken, the samples of the above items are considered to comply with the above standard.

Signed: *N. A. Jones*  
N A Jones  
Certifying Officer

Date of test: February 2001  
Date of issue: 16<sup>th</sup> March 2001

PBT Ltd  
1 Astra Centre  
Edinburgh Way  
Essex  
CM20 2BN

Serial No: 17061  
Report No: 00003250A/Issue 1

