File Ref. AST/68/1/56

25 July 1995

Bussmann Division Cooper (UK) Ltd., Burton-on-the-Wolds. Loughborough Leicestershire. LE12 5TH

For the attention of Mr. J. Peak



Dear Sirs,



Authority is hereby given for the fuse-link types and ratings identified below to be endorsed ASTA @ CERT. or ASTA @ CERTIFIED.

## Details of Reference Fuse-Links

British Standard No.:

BS 88 : Part 2, Sections 2.1 & 2.2 : 1988 (IEC 269-2 : 1986

& IEC 269-2-1, Section II: 1987)

Manufacturers Type Designation

ΕD

BS Ref. B4

& BS Ref. / Size / Types:

Voltage Rating:

415V ac

**Breaking Capacity:** 

80kA

Current Ratings:

63, (315), 355 and 400A

ASTA Certificate No(s):

11974 (Short-Circuit Rating)

Label Trade Name:

Bussmann

## **Approved Variants**

Details of approved variants (if any) are shown on attachments to this letter

This letter of authorisation is not valid until a signed acknowledgement of receipt has been received by ASTA. The signing of this letter by a manufacturer means ipso facto that the manufacturer agrees to recognise and to observe the requirements of the current issue of ASTA Publication No. 20.

Yours Faithfully.

Note: This Authorisation extends that of the same

reference issued 9th March 1993

Acknowledgement of reseigt is hereby given

Signed

Company

a1054a.doc

RETURN ONE SIGNED COPY TO ASTA



A Company Limited by Guarantee, Registered at London, Number 347056

Registered Office ASTA House, Chestnut Field, Rugby, Warwickshire CV21 2TL, UK. Telephone 01788 578435 Fax 01788 573605

Chief Executive Michael J. Swan, Dip.E.E., C.Eng., F.I.E.E., F.I.Q.A.



## AUTHORISATION TO USE THE ASTA CERT ENDORSEMENT Details of Approved Variants

File Ref.	Fuse Type Designation	Variation Details	Approved Date
AST/68/1/56/1	ED 315M 355 ED315M 400	Alternative designation BS 88-2 Ref. B4	9th March '93
AST/68/1/56/2	ED 63 to ED 400	Alternative disposition of end tag foot on end cap BS 88-2 ref B3/B4	9th March '93
AST/68/1/56/3	ED 315M 355 ED 315M 400	Alternative disposition of end tag on end cap and alternative designation BS 88-2 Ref B3.	9th March '93
AST/68/1/56/4	EF 63 EF 355 EF 400	Alternative end tag. BS 88-2 Ref C1	9th March <sup>1</sup> 93
AST/68/1/56/5	EF/EFS 63A 355A 400A	Alternative end tag and disposition on end cap BS 88-2 Ref C1.	9th March '93
		ASTA	
		M. J. hard	
			The control of the Management of the Control of the