



Certificate of Compliance

Certificate Number: LR 47574-14
KEMA Ref. 98.0793

Revision: LR 47574-27

Date Issued: March 18, 1998

Issued To: Wickmann Werke GmbH
Postfach 2520
58415 WITTEN
Germany

The products listed below are eligible to bear the CSA Mark.

Issued By: J. Pankowski
CSA Montreal

Signature

PRODUCTS

Cartridge Fuseholder Assemblies, 250 V, miniature extractor type, single pole.

<u>Type</u>	<u>Captype</u>	<u>Ratings (max)</u>
823	835	16 A
821	835	16 A
820	835	16 A
831	835	16 A
811	815 or 816	16 A
810	815 or 816	16 A
801	815 or 816	16 A
802	815 or 816	16 A
830	835	16 A
780	785 or 786	16 A
800	815 or 816	16 A
601	602	16 A
781	785 or 786	16 A
782	785 or 786	16 A
783	785 or 786	16 A



Certificate of Compliance

Certificate Number: LR 47574-14
KEMA Ref. 98.0793

Revision: LR 47574-27

Date Issued: March 18, 1998

<u>Type</u>	<u>Capttype</u>	<u>Ratings</u>
824	835	16 A
814	815 or 816	16 A
834	835	16 A
834	835 or 835-9	6.3 A

Cartridge Fuseholder Assemblies, 500 V, miniature extractor type, single pole.

<u>Type</u>	<u>Capttype</u>	<u>Ratings</u>
803	816	16 A

Notes:

- 1 The fuseholders are for use with supplemental type fuses.
- 2 The type designations may be completed with suffixes for mechanical details and may be preceded with the number 19.
- 3 The cartridge fuseholder assemblies are for use for only in equipment where the acceptability of the combination is to be determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0 - M91 - General Requirements
" " " " 39 - M1987 - Fuseholder Assemblies

Electrical Certification Notice No. 552B



CERTIFICATION RECORD

The company named below has been authorized by CSA to represent the products listed in this record as "CSA Certified" and to affix the CSA Mark to these products according to the terms and conditions of the CSA Service Agreement and applicable CSA program requirements (including additional Markings).

File No: 047574 0 000

Class No: 6225 01 FUSEHOLDER ASSEMBLIES

SUBMITTOR

47283 Wickmann-Werke GmbH
Annenstrasse 113
Witten, D-58453
GERMANY

FACTORY

47283 Wickmann-Werke GmbH
Annenstrasse 113
Witten, D-58453
GERMANY

March 18, 1998(Replaces:February 11, 1998)

TO THE REQUIREMENTS OF C22.2 NO 39-M1987, ECN 552, 552A:

- Cartridge fuseholder assemblies (may be for PCB mounting), for 250V, miniature extractor type, single pole

Type	Capttype	Ratings
823	835	16A
821	835	16A
820	835	16A
831	835	16A
811	815 or 816	16A
813	815 pr 816	16A
810	815 or 816	16A
801	815 or 816	16A
802	815 or 816	16A
830	835	16A



780	785 or 786	16A
800	815 or 816	16A
601	602	16A
781	785 or 786	16A
782	785 or 786	16A
783	785 or 786	16A
824	835	16A
652	653 or 655	16A
803	816	16A
814	815 or 816	16A
834	835 or 835-9	6.3A

- Cartridge fuseholder assemblies, 500V, miniature extractor type, single pole.

Type	Capttype	Ratings
803	816	16A

Notes:

1. These fuseholders are for use with supplemental type fuses.
2. The type designations may be completed with suffixes for mechanical details.
3. The spacings from live parts of the fuseholder 601 to the grounded or dead metal parts of the equipment shall be in accordance with the requirements of the equipment in which the fuseholders are installed.
4. The cartridge fuseholder assemblies are for use only in equipment where the acceptability of the combination is to be determined by the Canadian Standards Association.

cl