Certificate of Compliance

Certificate Number: LR 108291-1

KEMA Ref. 96.1246

Revision: LR 108291-1

Date Issued: May 29, 1996

Issued To: WERMA Signalgeräte

GmbH & Co.

Duerbheimer Strasse 15 D-78604 Rietheim-Weilheim

Germany

The products listed below are eligible to bear the CSA Mark.

Issued By: J. Pankowski

CSA Montreal

PRODUCTS

System Kombi SIGN, enclosed Type 2 and 5 consisting of the following:

Signal Lights; Cat. No. 840 - followed by 100, 200, 300, 400 or 500 followed by 00, rated 240V ac max.

Signal Lights Base, Cat. No. 840 - followed by 080, 085 followed by 00, nonelectrical.

Signal Light Buzzer Element, Cat. No. 844 - followed by 118 followed by 55 rated 24V ac/dc, 67 rated 115V ac or 68 rated 230V ac.

Signal Lights Blinking Light Element, Cat. No. 841 - followed by 100, 200, 300, 400 or 500 followed by 55 rated 150 mA 24V ac/dc or 68 rated 15 mA 230V ac.

Signal Lights Flash Light Element, Cat. No. 842 - followed by 100, 200, 300, 400 or 500 followed by 55 rated 125 mA 24V ac/dc or 68 rated 15 mA 230V ac.

Signal Lights LED-Light Element, Cat. No. 843 - followed by 100, 200, 300, 130, 230, 330 rated 70 mA 24V ac/dc or 110, 210, 310 rated 40 mA 24V ac/dc, followed by 55.

Non Electrical Accessories, Cat. No. 975 followed by 840 followed by 00, 10, 85 or 86.

DQD 507

Page 1/2



Certificate of Compliance

Certificate Number: 108291-1

KEMA Ref. 96.1246

Revision: 108291-1 Date Issued: May 29, 1996

Notes:

- 1. These devices are the components which make a stackable tower light system (max lights on the stack 5) and may be topped with a cap or a buzzer element. They are suitable for use as part of the overall enclosure.
- 2. These are Certified only for supply to manufacturers for the assembly, as components, of certified electrical equipment where the suitability of the combination is determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0 - M91 - General Requirements

" " 0.6 - M1982 - Flammability of Polymeric Materials

" " 14 - M95 - Industrial Control Equipment

" " 94 - M91 - Special Purpose Enclosures

DQD 507