

File Ref. AST/68/2/100

03 August 1995

Bussmann Division Cooper (UK) Ltd.,
Burton-on-the Wolds, Loughborough,
Leicestershire. LE12 5TH.

For the attention of Mr. J. Peak



Dear Sirs



**AUTHORISATION TO USE THE ASTA CERT ENDORSEMENT
AUTHORISATION REF. A2100B**

Authority is hereby given for the fuse-link types and ratings identified below to be endorsed
ASTA ²⁰CERT. or ASTA ²⁰CERTIFIED.

Details of Reference Fuse-Links

British Standard No.:	BS 88 : Part 2, Sections 2.1 & 2.2 : 1988 (IEC 269-2 : 1986 & IEC 269-2-1 Section II : 1987)
Manufacturers Type Designation & BS Ref. / Size / Types:	AAO/H07 (BS Ref. A2).
Voltage Rating:	550V ac
Breaking Capacity:	80kA ac
Current Ratings:	100*, 80*, 63*, 50*, 45*, 40*, 35*, 32, 25, 20, 16A and 10A * These ratings not BS Ref. A2
ASTA Certificate No(s):	11529 (Short-Circuit)
Label Trade Name:	Bussmann

Approved Variants

Details of approved variants (if any) are shown on attachments to this letter

This letter of authorisation is not valid until a signed acknowledgement of receipt has been received by ASTA. The signing of this letter by a manufacturer means ipso facto that the manufacturer agrees to recognise and to observe the requirements of the current issue of ASTA Publication No. 20.

Note: This Authorisation extends that of the same reference issued 18th May 1995.

Acknowledgement of receipt is hereby given

Yours Faithfully,

SIGNED
for Bussmann Division, Cooper (U.K.) Ltd. Company

RETURN ONE SIGNED COPY TO ASTA
Issue 5, June 1995

20th March 1996 Date

a2100b.doc



A Company Limited by Guarantee, Registered at London, Number 347056

Registered Office: ASTA House, Chestnut Field, Rugby, Warwickshire CV21 2TL, UK.
Telephone 01788 578435 Fax 01788 573605

Chief Executive Michael J. Swan, Dip.E.E., C.Eng., F.I.E.E., F.I.Q.A.