



# Certificate of Compliance

Certificate Number: LR 12400-368  
KEMA Ref. 97.3975

Revision: LR 12400-381

Date Issued: October 22, 1997

Issued To: Weidmüller Interface  
GmbH & Co.  
P.O. Box 3030  
32720 Detmold  
Germany

*The products listed below are eligible to bear the CSA Mark.*

Issued By: J. Pankowski  
CSA Montreal

Signature

FOR  


## PRODUCTS

Terminal Block Connector System Types BLZF/SLZF (sockets/headers)

Type	Voltage (V) Group & Designation	Current Rating (A)	Wire Range (AWG)	Stripping Length (mm)
BLZF/SLZF	300 B	15	26-14	7
	300 D	10	26-14	7
	300 E	-	26-14	7

## Notes:

- 1 These terminal blocks are Certified only for supply to manufacturer's for the assembly, as components, of Certified electrical equipment where the suitability of the combination is determined by the Canadian Standards Association.
- 2 Not approved for interrupting current.



## Certificate of Compliance

Certificate Number: LR 12400-368  
KEMA Ref. 97.3975

Revision: LR 12400-381

Date Issued: October 22, 1997

- 
- 3 Terminal blocks specified for Group Designation E shall be used with equipment of limited rating, as permitted by the applicable CSA Standard (C22.2 Series) covering the end product in which the terminal block is installed.
  - 4 Suffixes may be added to the Catalogue number to denote the pitch and the number of terminals.

### APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0 - M91 - General Requirements  
" " 158 - M1987 - Terminal Blocks