

Certificate of Compliance

Certificate: 1244019 (LR 12400-279)

Master Contract: 154685

Project: 1390651

Date Issued: January 29, 2003

Issued to: Weidmuller Ltd.
 10 Spy Crt.
 Markham, ON L3R 5H6
 CANADA

The products listed below are eligible to bear the CSA Mark shown




Authorized by: Davey Li, P. Eng.
 Manager - Engineering

PRODUCTS

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

Heavy current modular rail mounted terminal blocks. Types WFF35-300 (Cat Nos. 102830, 102840, etc), for TS32 and TS35 mounting rails, Types WF6-12 for TS35 mounting rails, stud terminal to stud terminal, for lugs on copper conductors, as following:

| <u>Type</u> | <u>Rating</u> | | <u>Spacings</u> | <u>Wire Range</u> | <u>Assigned</u> | <u>Stud</u> |
|-------------|------------------|--------------|-----------------|-------------------|-----------------|-------------|
| | <u>Amp (Max)</u> | <u>Volts</u> | | | | |
| WF5 | 85 | 1000 | C | 10-4 | 2 | M5 |
| WF6 | 150 | 1000 | C | 14-2 | 16.9 | M6 |
| WF8 | 200 | 1000 | C | 14-1/0 | 20.3 | M8 |
| WF10 | 320 | 1000 | C | 10-250 kemil | 36.2 | M10 |
| WF12 | 320 | 1000 | C | 10-250 kemil | 36.2 | M12 |

Certificate: 1244019
Project: 1244019

Master Contract: 154685
Date: December 18, 2001

| <u>Type</u> | <u>Rating</u> | | <u>Spacings</u> | <u>Wire Range</u> | <u>Assigned</u> | <u>Stud</u> |
|-------------|------------------|--------------|-----------------|-------------------|-----------------|-------------|
| | <u>Amp (Max)</u> | <u>Volts</u> | | | | |
| WFF35 | 130 | 600 | B, C, D | 14-2 | 4.5 | M6 |
| WFF70 | 170 | 600 | B, C, D | 14-2/0 | 10 | M8 |
| WFF120 | 310 | 600 | B, C, D | 10-250 kemil | 15 | M10 |
| WFF185 | 360 | 600 | B, C, D | 8-500 kemil | 20 | M12 |
| WFF300 | 510 | 600 | B, C, D | 6-6000 kemil | 40 | M16 |

Notes:

1. These are Certified only for supply to manufacturers for the assembly, as components, of Certified electrical equipment where the suitability of the combination is determined by the Canadian Standards Association.
2. Types WF6, WF8, WF10 and WF12 provided with barriers to obtain requested spacings for Type WF6 barrier type WTW, WF6, Type WF8 barrier type WTW, WF8, Types WF10 and WF12 barrier type WTW WF10/WF12.

APPLICABLE REQUIREMENTS

| | | |
|----------------------------|---|---|
| CAN/CSA-C22.2 No. 0-M91 | - | General Requirements - Canadian Electrical Code, Part II |
| CSA Std C22.2 No. 158-1987 | - | Terminal Blocks |
| Electrical Notice 584B | - | Publication of Amendments to CSA Standard C22.2 No. 158-1987, "Terminal Blocks" |

Supplement to Certificate of Compliance

Certificate: 1244019 (LR12400-279)

Master Contract: 154685

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

| Project | Date | Description |
|----------------|------------------|--|
| 1390651 | January 29, 2003 | CSA – Update to report 1244019 to cover new type WF5. |
| 1244019 | Dec. 18, 2001 | CSA – Conversion of report to new CSA SAP numbering system and update LR 12400-279 to cover new types WF6, WF8, WF10 and WF12. <i>Report 154685-1244019 supersedes Report LR 12400-279.</i> |