SIEMENS

Data sheet

6AV7863-1MA00-2AA0



SIMATIC IFP1200 V2; 12" multi-touch display (16:10) with 1280x800 pixel resolution; built-in unit for 24 V DC, display port/DVI interface including DP/USB cable 1.8 m; USB on the rear side; standard design

General information	
Product type designation	IFP1200
Short designation	Flat Panel 12" multi-touch
Display	
Design of display	TFT widescreen display, LED backlighting
Screen diagonal	12.1 in
Screen diagonal [cm]	30.7 cm
Display width	261.1 mm
Display height	163.2 mm
On Screen Display (OSD) configuration	No
Number of colors	16 777 216; 24 bit
Viewing angle	176° x 176°
Resolution (pixels)	
 Image resolution 	1 280 x 800
 Horizontal image resolution 	1 280 pixel
 Vertical image resolution 	800 pixel
 Pixel size, horizontal 	0.204 mm
Pixel size, vertical	0.204 mm
General features	
 Brightness/contrast 	400 cd/m ² / 800:1
 Detachable from computer unit 	5 m
Luminance	400 cd/m ²
Backlighting	
 Type of backlighting 	LED
 MTBF backlighting (at 25 °C) 	70 000 h; At 25°C
 Backlight dimmable 	Yes; 0-100 %
Control elements	
Input device	
 Integrated mouse cursor control 	Yes; Also externally via USB
Touch operation	
 Design as touch screen 	Yes
 Design as multi-touch screen 	Yes; Projective-capacitive
 Monitor keyboard 	Yes
Installation type/mounting	
Design	Built-in unit
Front mounting	Yes
Mounting in portrait format possible	Yes
Mounting in landscape format possible	Yes
Built-in unit	Yes; Portrait mode possible

maximum permitted forward tilt angle from vertical	35°
maximum permitted forward tilt angle from vertical maximum permitted backward tilt angle from vertical	35°
Supply voltage	JJ
Type of supply voltage	DC 24 V: PELV / SELV floating
Rated value (DC)	24 V; PELV / SELV floating 19.2 V
permissible range, lower limit (DC)	
permissible range, upper limit (DC)	28.8 V
Input current	
Current consumption (rated value)	0.65 A
Current consumption, max.	1A
Starting current inrush I ² t	0.5 A ² ·s
Power loss	
Power loss, typ.	15 W
Power loss, max.	25 W
Interfaces	
Number of USB interfaces	2; USB 2.0 type A
USB on the rear	Yes; 2x onboard
Connection for keyboard/mouse	USB
Video interfaces	No.
• DVI-D	Yes
DisplayPort	Yes; Display port V1.2
Touch interfaces	Vee
• USB	Yes
Degree and class of protection	
IP (at the front)	IP65
IP (rear)	IP20
NEMA (front)	
Enclosure Type 4 at the front	Yes
• Enclosure Type 4x at the front	Yes
Enclosure Lype 12 at the trent	Yes
Enclosure Type 12 at the front	
Standards, approvals, certificates	
Standards, approvals, certificates Certificate of suitability	hazardous zone 2/22; shipbuilding
Standards, approvals, certificates Certificate of suitability CE mark	hazardous zone 2/22; shipbuilding Yes
Standards, approvals, certificates Certificate of suitability CE mark UL approval	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK)	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R)	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes Yes
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 2	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 2 • IECEx Zone 22	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 2 • IECEx Zone 2 • FM Class I Division 2	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes <
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2 Marine approval • Germanischer Lloyd (GL)	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2 Marine approval • Germanischer Lloyd (GL) • American Bureau of Shipping (ABS)	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes <
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2 Marine approval • Germanischer Lloyd (GL) • American Bureau of Shipping (ABS) • Bureau Veritas (BV)	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 2 • IECEx Zone 2 • FM Class I Division 2 Marine approval • Germanischer Lloyd (GL) • American Bureau of Shipping (ABS) • Bureau Veritas (BV) • Det Norske Veritas (DNV)	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes <
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 2 • IECEx Zone 2 • FM Class I Division 2 Marine approval • Germanischer Lloyd (GL) • American Bureau of Shipping (ABS) • Bureau Veritas (BV) • Det Norske Veritas (DNV) • Lloyds Register of Shipping (LRS)	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes; In application process
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2 Marine approval • Germanischer Lloyd (GL) • American Bureau of Shipping (ABS) • Bureau Veritas (BV) • Det Norske Veritas (DNV) • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (Class NK)	hazardous zone 2/22; shipbuilding Yes Yes; CULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes; In application process Yes; In application process
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Marine approval • Germanischer Lloyd (GL) • American Bureau of Shipping (ABS) • Bureau Veritas (BV) • Det Norske Veritas (DNV) • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (Class NK)	hazardous zone 2/22; shipbuilding Yes Yes; CULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes Yes; In application process Yes; In application process
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 2 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2 Marine approval • Germanischer Lloyd (GL) • American Bureau of Shipping (ABS) • Bureau Veritas (BV) • Det Norske Veritas (DNV) • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (Class NK)	hazardous zone 2/22; shipbuilding Yes Yes; CULus, CUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes <
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Marine approval • Germanischer Lloyd (GL) • American Bureau of Shipping (ABS) • Bureau Veritas (BV) • Det Norske Veritas (DNV) • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (Class NK) Ambient conditions Ambient temperature during operation • min.	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Marine approval • Germanischer Lloyd (GL) • American Bureau of Shipping (ABS) • Bureau Veritas (BV) • Det Norske Veritas (DNV) • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (Class NK) Ambient conditions Ambient temperature during operation • min. • max.	hazardous zone 2/22; shipbuilding Yes Yes; CULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes <
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Marine approval • Germanischer Lloyd (GL) • American Bureau of Shipping (ABS) • Bureau Veritas (BV) • Det Norske Veritas (DNV) • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (Class NK) Ambient temperature during operation	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes <
Standards, approvals, certificates Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2 Marine approval • Germanischer Lloyd (GL) • American Bureau of Shipping (ABS) • Bureau Veritas (BV) • Det Norske Veritas (DNV) • Lloyds Register of Shipping (LRS) • Nippon Kaiji Kyokai (Class NK) Ambient conditions Ambient temperature during operation • min. • max.	hazardous zone 2/22; shipbuilding Yes Yes; cULus, cUL Yes; Corresponds to UL 508 Yes; Available soon Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes

Altitude during operation relating to sea level	
 Installation altitude above sea level, max. 	3 500 m
Relative humidity	
 Operation, max. 	95 %; no condensation
Vibrations	
 Vibration load in operation 	1 gn
 Vibration load during transport/storage 	1 gn
Shock testing	
 Shock load during operation 	15 gn
 shock acceleration during storage/transport 	15 gn
Mechanics/material	
Enclosure material (front)	In standard design
Aluminum	Yes
Aluminum casting	Yes
• Glass	Yes; at front
Enclosure material (rear)	aluminum
Dimensions	
Width of the housing front	326 mm
Height of housing front	237 mm
Mounting cutout, width	310 mm; Tolerance: +1 mm
Mounting cutout, height	221 mm; Tolerance: +1 mm
Overall depth	62.5 mm
Weights	
Weight (without packaging)	3 kg
Weight (with packaging)	4.4 kg
last modified:	1/24/2022 🖸

last modified:

1/24/2022 🖸